

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.-UPJN/A4R/26/06/513

Dated: - 10/06/2026

It is certified that an inspection team headed by Er. Vipin Agarwala / Amita Devi (chemist)

(Name of Officers with designation) from UP Jal Nigam (Rural) Aggra PHED

inspected the Rising Sun Premier School, Danda Crossing, Jagher, Aggra

(Name & Address of the school) on 08/06/2026....(date of inspection) and on the basis of

Water Test Report (Attached) bearing no. UPJN/A4R/26/06/513... dated 10/06/2026

of Regional water testing laboratory Aggra PHED Lab) certified that

the Rising Sun Premier School... (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till one year from issue date

सहायक अभियन्ता
खण्ड कार्यालय, 10-06-2026

Signature with Seal: उपप्र. जल निगम (ग्रामीण)

Name : Vipin Agarwala

Designation : (A.E.)

Name & Address of the Office / Department : UP Jal Nigam (Rural) Aggra

To Principal
Rising Sun Premier School, Jagher, Aggra
(Name & Address of the Institution)

Amita

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Regional Level Water Analysis Laboratory

Address: 4/4 Sanjay Palace U.P. Jal Nigam(Rural) Agra, 282002



TEST REPORT

Report No:	UPJN/AGR/26/06/513	Issue Date:	10/06/2026	Page No	1/2
Customer Details					
Office Name and Address	PRINCIPAL RISING SUNPREMIER SCHOOL ,DANDACROSSING,JAGNER,AGRA				
Ref Letter No & Date	RSPS/06/2026 &05/06/2026				
Basic details of sample					
District	Agra	Block	JAGNER		
Gram Panchayat	-	Village/city	JAGNER		
Water Source	RO WATER	Location	RISING SUNPREMIER SCHOOL		
Quantity of Sample	1 Lt.	Sample No.	01		
Receiving Date	08/06/2026	Date of Collection	80/06/2026		
Sample Depositor	Mr.Mr.subhendra	S. Collector	Mr.subhendra		
Analysis Start Date	08/06/2026	Sampling Method	As per IS 17614: Part 1: 2021		
		Analysis Completion Date:	09/06/2026		
Technical Data of Analysis					
S.No.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS, 10500:2012		Ref. Method of Analysis Joint testing(100-130)
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH (@ 25°C)	7.28	6-8.5	6.5-8.5	IS 3025 (Part 11):2022 (Electrometric method)
2	Turbidity mg/L	0.904	1	5	IS 3025 (Pt 10):1984 (Nephelometric Method)
3	Total Dissolved Solid mg/L	124	500	2000	IS 3025 (Pt 16):1984 (Gravimetric Method)
4	Fluoride mg/L	0.824	1	1.5	APHA 24 rd Edition 4500-F Method C (Electrode method) 2017
5	Total Hardness mg/L	48	200	600	IS 3025 (Part 21):2009(EDTA Method)
6	Total Alkalinity mg/L	52	200	600	IS 3025 (Part 24):1986 (Potentiometric method)
7	Chloride mg/L	34	250	1000	IS 3025 (Part 32):1988 (Argentometric method)
8	Iron mg/L	0.01	1	1	APHA 24 rd Edition 3500-Fe Method B (Phenanthroline Method) 2017
9	Sulphate mg/L	02	200	400	APHA 24 rd Edition 4500-SO4 Method E (Turbidity Method) 2017
10	Calcium mg/L	28	75	200	IS 3025 (Part 40):1991(EDTA Titrimetric Method)
11	Magnesium mg/L	7.33	30	100	IS 3025 (Part 46):1994(Volumetric Method)
12	Color (Hazen)	01	5	15	APHA 24 rd Edition Color 2120 B (Visual Comparison Method)
13	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (PART 08) 1984 (Qualitative Method)



Regional Level Water Analysis Laboratory

Address: 4/4 Sanjay Palace U.P. Jal Nigam(Rural) Agra, 282002



14	Nitrate (mg/l)	nil	45	45	APHA 24 Edition -4500 NO3 method B (UV Spectrophotometric method:2023)
----	----------------	-----	----	----	--

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
5. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
6. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
7. Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests reports.

Laboratory Contact detail

Amita
(Amita Devi)
Authorized Signatory:
Testing Lab In charge
Mob. 8630975287
MANAGER
Regional Jal Nigam (R) Agra